

## Appliance - Split type air conditioner

Directive 2009/125/EC

|                  |                  |
|------------------|------------------|
| Supplier         | Carrier          |
| Outdoor unit     | 38WHSM042A1A0TEE |
| Indoor unit 1    | 40WHMW042D1A0TEE |
| Capacity control | Variable         |

### Cooling

|                                      |                           |    |      |
|--------------------------------------|---------------------------|----|------|
| Design load                          | P <sub>designc</sub>      | kW | 4.2  |
| Seasonal efficiency                  | SEER                      |    | 7.00 |
| Seasonal electricity consumption (*) | Q <sub>ce</sub> kWh/annum |    | 210  |
| Degradation co-efficient cooling     | C <sub>dc</sub>           |    | -    |

Declared capacity for cooling, at indoor temperature 27(19) °C and outdoor temperature T<sub>j</sub>

|                       |                 |    |      |
|-----------------------|-----------------|----|------|
| T <sub>j</sub> = 35°C | P <sub>dc</sub> | kW | 4.20 |
| T <sub>j</sub> = 30°C | P <sub>dc</sub> | kW | 3.09 |
| T <sub>j</sub> = 25°C | P <sub>dc</sub> | kW | 1.99 |
| T <sub>j</sub> = 20°C | P <sub>dc</sub> | kW | 1.20 |

Declared energy efficiency ratio, at indoor temperature 27(19) °C and outdoor temperature T<sub>j</sub>

|                       |                 |    |       |
|-----------------------|-----------------|----|-------|
| T <sub>j</sub> = 35°C | P <sub>dc</sub> | kW | 3.31  |
| T <sub>j</sub> = 30°C | P <sub>dc</sub> | kW | 5.35  |
| T <sub>j</sub> = 25°C | P <sub>dc</sub> | kW | 9.05  |
| T <sub>j</sub> = 20°C | P <sub>dc</sub> | kW | 11.63 |

### Heating

|                                      |                           | Average climate | Colder climate | Warmer climate |       |
|--------------------------------------|---------------------------|-----------------|----------------|----------------|-------|
| Design load                          | P <sub>designh</sub>      | kW              | 3.6            | -              | 1.9   |
| Seasonal efficiency                  | SCOP                      |                 | 4.60           | -              | 5.60  |
| Seasonal electricity consumption (*) | Q <sub>he</sub> kWh/annum |                 | 1095           | -              | 479   |
| Bivalent temperature                 |                           | °C              | -7.0           | -15.0          | 2.0   |
| Operation limit temperature          |                           | °C              | -15.0          | -15.0          | -15.0 |
| Degradation co-efficient heating     | C <sub>dh</sub>           |                 | -              |                |       |

### Average climate

Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature T<sub>j</sub>

|  |                 |    |      |
|--|-----------------|----|------|
| T <sub>j</sub> = -7 °C                       | P <sub>dh</sub> | kW | 3.18 |
| T <sub>j</sub> = +2 °C                       | P <sub>dh</sub> | kW | 1.94 |
| T <sub>j</sub> = +7 °C                       | P <sub>dh</sub> | kW | 1.25 |
| T <sub>j</sub> = +12 °C                      | P <sub>dh</sub> | kW | 1.00 |
| T <sub>j</sub> = bivalent temperature        | P <sub>dh</sub> | kW | 3.18 |
| T <sub>j</sub> = operation limit temperature | P <sub>dh</sub> | kW | 2.30 |

Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature T<sub>j</sub>

|  |                 |    |      |
|--|-----------------|----|------|
| T <sub>j</sub> = -7 °C                       | P <sub>dh</sub> | kW | 2.80 |
| T <sub>j</sub> = +2 °C                       | P <sub>dh</sub> | kW | 4.70 |
| T <sub>j</sub> = +7 °C                       | P <sub>dh</sub> | kW | 6.15 |
| T <sub>j</sub> = +12 °C                      | P <sub>dh</sub> | kW | 6.70 |
| T <sub>j</sub> = bivalent temperature        | P <sub>dh</sub> | kW | 2.80 |
| T <sub>j</sub> = operation limit temperature | P <sub>dh</sub> | kW | 2.40 |

### Electricity

|                          |                  |    |       |                       |                 |    |       |
|--------------------------|------------------|----|-------|-----------------------|-----------------|----|-------|
| off mode                 | P <sub>off</sub> | kW | 0.001 | standby mode          | P <sub>sb</sub> | kW | 0.001 |
| thermostat-off mode      | P <sub>to</sub>  | kW | 0.039 | Crankcase heater mode | P <sub>ck</sub> | kW | 0.000 |
| Back up heating capacity |                  | kW |       |                       |                 |    | 0.000 |

Declared capacity for heating, at indoor temperature 20°C and outdoor temperature T<sub>j</sub>.

|  |                 |    |      |   |      |
|--|-----------------|----|------|---|------|
| T <sub>j</sub> = -7 °C                       | P <sub>dh</sub> | kW | 3.18 | - | -    |
| T <sub>j</sub> = +2 °C                       | P <sub>dh</sub> | kW | 1.94 | - | 1.90 |
| T <sub>j</sub> = +7 °C                       | P <sub>dh</sub> | kW | 1.25 | - | 1.22 |
| T <sub>j</sub> = +12 °C                      | P <sub>dh</sub> | kW | 1.00 | - | 1.00 |
| T <sub>j</sub> = bivalent temperature        | P <sub>dh</sub> | kW | 3.18 | - | 1.90 |
| T <sub>j</sub> = operation limit temperature | P <sub>dh</sub> | kW | 2.30 | - | 2.30 |

(\*) Based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located

## Refrigerant

|                          |                          |     |
|--------------------------|--------------------------|-----|
| Type                     |                          | R32 |
| Global Warming Potential | GWP kgCO <sub>2</sub> eq | 675 |

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 1975. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 1975 times higher than 1 kg of CO<sub>2</sub>, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional

| Sound power level            |    | Cooling | Heating |
|------------------------------|----|---------|---------|
| Outdoor unit                 | dB | 63      | 64      |
| Indoor unit 40WHMW042D1A0TEE | dB | 56      | 56      |

| Rated air flow               |                   | Cooling | Heating |
|------------------------------|-------------------|---------|---------|
| Outdoor unit                 | m <sup>3</sup> /h | 2160    | 2160    |
| Indoor unit 40WHMW042D1A0TEE | m <sup>3</sup> /h | 750     | 760     |

| Dimensions                   | Height | Width | Depth | Weight (kg) |
|------------------------------|--------|-------|-------|-------------|
| Outdoor unit                 | m      |       | 2160  | 2160        |
| Indoor unit 40WHMW042D1A0TEE | m      |       | 750   | 760         |

Harmonised standard EN14511:2007 , EN12102

Calculation methods - Measurement standards EN14511:2007 , EN12102

## Contact details

RIELLO Spa  
Via Ing. Pilade Riello, 7 - 37045 Legnago (VR), Italy