

Subtype DAIKIN ALTHERMA 4 H W+F 06-10 kW 180L (1 ph)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 4 H W+F 06-10 kW 180L (1 ph)
Registration number	011-1W0934
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1 kg
Certification Date	05.12.2024
Testing basis	HP KEYMARK certification scheme rules rev. 14

Model EPSK06AV3 / EPVX10S18A(4V/9W)

Model name	EPSK06AV3 / EPVX10S18A(4V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	117.3 %
COP	2.93
Heating up time	1:13 h:min
Standby power input	42.1 W
Reference hot water temperature	47 °C
Mixed water at 40°C	203.6 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.81 kW	6.08 kW
El input	1.12 kW	1.76 kW
COP	5.19	3.46

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.55 kW	
Cooling capacity	6	
EER	3.87	

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	45 dB(A)	45 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	202 %	153 %
Prated	6.50 kW	6.50 kW
SCOP	5.12	3.91
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.70 kW
COP Tj = -7°C	3.49	2.65
Cdh Tj = -7 °C	1.000	
Pdh Tj = +2°C	3.40 kW	3.50 kW
COP Tj = +2°C	5.04	3.86
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	2.50 kW	2.30 kW
COP Tj = +7°C	6.37	4.68
Cdh Tj = +7 °C	0.900	1.000
Pdh Tj = 12°C	2.90 kW	2.80 kW
COP Tj = 12°C	8.15	6.38
Cdh Tj = +12 °C	0.900	1.000
Pdh Tj = Tbiv	5.80 kW	5.70 kW
COP Tj = Tbiv	3.49	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.80 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.38
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	21 W	21 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	0.29 kW
Annual energy consumption Qhe	2624 kWh	3438 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	6 kW	
SEER	5.38	
Pdc Tj = 35°C	6 kW	
EER Tj = 35°C	3.87	

Pdc Tj = 30°C	4.61 kW
EER Tj = 30°C	5.21
Cdc Tj = 30 °C	0.98
Pdc Tj = 25°C	2.81 kW
EER Tj = 25°C	6.79
Cdc Tj = 25 °C	0.95
Pdc Tj = 20°C	6.64 kW
EER Tj = 20°C	5.98
Cdc Tj = 20 °C	0.98
Poff	21 W
PTO	21 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	670 kWh