

## Subtype DAIKIN ALTHERMA 4 H W+F 12-14 kW 180L (3ph)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 4 H W+F 12-14 kW 180L (3ph)
Registration number	011-1W0930
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.25 kg
Certification Date	05.12.2024
Testing basis	HP KEYMARK certification scheme rules rev. 14

## Model EPSK14AW1 / EPVX14S18A(4V9W)

Model name	EPSK14AW1 / EPVX14S18A(4V9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	121.2 %
COP	3.03
Heating up time	1:09 h:min
Standby power input	35.5 W
Reference hot water temperature	47 °C
Mixed water at 40°C	203.6 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.2 kW	10.91 kW
El input	1.86 kW	3.03 kW
COP	5.5	3.6

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3.45 kW	
Cooling capacity	11.3	
EER	3.28	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	195 %	150 %
Prated	12.00 kW	14.00 kW
SCOP	4.96	3.84
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.90 kW	12.40 kW
COP Tj = -7°C	3.45	2.52
Cdh Tj = -7 °C	1.000	
Pdh Tj = +2°C	6.70 kW	8.00 kW
COP Tj = +2°C	4.58	3.52
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	8.00 kW	5.10 kW
COP Tj = +7°C	6.67	5.38
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	8.60 kW	7.70 kW
COP Tj = 12°C	8.42	6.50
Cdh Tj = +12 °C	1.000	1.000
Pdh Tj = Tbiv	12.50 kW	14.30 kW
COP Tj = Tbiv	3.18	2.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	14.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.18	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	35 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4999 kWh	7537 kWh

## EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	11 kW	
SEER	5.12	
Pdc Tj = 35°C	11.3 kW	
EER Tj = 35°C	3.28	

Pdc Tj = 30°C	8.01 kW
EER Tj = 30°C	4.6
Cdc Tj = 30 °C	0.99
Pdc Tj = 25°C	5.21 kW
EER Tj = 25°C	6.13
Cdc Tj = 25 °C	0.99
Pdc Tj = 20°C	7.21 kW
EER Tj = 20°C	5.87
Cdc Tj = 20 °C	0.99
Poff	22 W
PTO	22 W
PSB	22 W
PCK	0 W
Annual energy consumption Qce	1289 kWh